COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR										
1	Manufacturer: Kaishan Compressor USA									
	Model Number	r: KRSD-	100-115 VSD		Date:	06/30/20				
2	X Air-c	cooled V	Vater-cooled		Type:	Screw				
					# of Stages:	1				
3*	Full Load Operating Pressure b			115	psig b					
4	Drive Motor Nominal Rating			100	hp					
5	Drive Motor Nominal Efficiency			94.1	percent					
6	Fan Motor Nominal Rating (if applicable)			3	hp					
7	Fan Motor Nor	Fan Motor Nominal Efficiency			percent					
	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	97.7			490	19.94					
8*	75.9			392	19.36					
	66.0			343	19.24					
	48.3			245	19.71					
	41.5		. 1	196	21.17					
9*	Total Package Input Power at Zero Flow c, d			0.0 72.26	kW					
10	Isentropic Effic	Isentropic Efficiency				%				
11	Specific Power (kW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 10.00 0 25 50	Note: Graph is only a vie: Y-Axis Scale, 10 to 35,	75 200 225 250 275 300 325 Capacity (ACFM) issal representation of the data in + SkW/100acfm increments if neces 0 to 25% over maximum capacity	Section 8	25 450 475 500 525				

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate secified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.