## **COMPRESSOR DATA SHEET**



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR										
1	Manufacturer: Kaishan Compressor USA									
	Model Number	r: KRSD-200	)-125 VSD		Date:	06/30/20				
2	X Air-cooled Water-cooled				Type:	Screw				
					# of Stages:	1				
3*	Full Load Oper	Full Load Operating Pressure b			Ü	psig <sup>b</sup>				
4	Drive Motor Nominal Rating			200	hp					
5	Drive Motor Nominal Efficiency			95.4	percent					
6	Fan Motor Nominal Rating (if applicable)			(4) 1.0	hp					
7	Fan Motor Nominal Efficiency		83.5	percent						
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>					
	175.3		878	19.97						
8*	121.1			610	19.85					
	104.0			527	19.73					
	90.1			439	20.52					
	74.3			351	21.17					
9*		Total Package Input Power at Zero Flow c, d			kW					
10	Isentropic Effic	Isentropic Efficiency			%					
11	Specific Power (RW/100 ACFM)	Not	e: Graph is only a vi -Axis Scale, 10 to 35,	(62535(67540042545047550062555(6750)  Capacity (ACFM)  susual representation of the data in + 5kW/100acfm increments if neces 0 to 25% over maximum capacity	Section 8	50775800825850875900925				

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	olume Flow Rate secified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1/- 10/0
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.