COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR										
1	Manufacturer: Kaishan Compressor USA									
	Model Number	: KRSD-30-125 V	SD			06/30/20				
2	X Air-cooled Water-cooled				Type: Screw					
					# of Stages:	1				
3*	Full Load Oper		125	psig						
4	Drive Motor N		30	hp						
5	Drive Motor N		92.0	percent						
6	Fan Motor Nominal Rating (if applicable)		ble)	1	hp					
7	Fan Motor Nor	ninal Efficiency		83.5	percent					
	Input Power (kW)		Capaci	ty (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	31.3			142	22.04					
8*	26.1			114	22.89					
	23.5			99	23.74					
	18.1			71	25.49					
	15.9		o d	57	27.89					
9*	Total Package		0.0	kW						
10	Isentropic Efficiency			52.14		%				
11	Specific Power (RW/100 ACFM)	Note: Y-Axis Scal	Capacity (ACI t is only a visual represent le, 10 to 35, + 5kW/100acfr Axis Scale, 0 to 25% over	ation of the data in n increments if neces		125 150				

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1/- 10/0
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.