COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer:	Kaishan Compressor L	JSA						
	Model Number: KRSP-125-125 VSD			Date: 08/30/20					
2	X Air-cooled	Water-cooled		Type:	Screw				
			#	of Stages:	1				
3*	Full Load Operating Pressure b		125	<u> </u>	psig ^b				
4	Drive Motor Nominal Rating		125	hp					
5	Drive Motor Nominal Efficiency		95.4	percent					
6	Fan Motor Nominal Rating (if applicable)		5	hp					
7	Fan Motor Nominal	an Motor Nominal Efficiency 89.5		percent					
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	124.9		601	20.78					
	83.2		412	20.19					
	60.1		287	20.94					
	49.2		224	21.96					
	33.3		136	24.49					
9*	Total Package Input Power at Zero Flow c, d		0.0	kW					
10	Isentropic Efficiency		72.61	%					
11	35.00 30.00 25.00 15.00 20.00 15.00 25 50 75 100 125 150 175 200 225 250 275 300 325 350 375 400 425 450 475 500 525 550 575 600 625 650 Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity								

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Specific Energy Volume Flow Rate Consumption		No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.