



KAISHAN In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Kaishan Compressor USA		
	Model Number: KRSP-125-150	Date:	6/30/2020
2	Air-cooled X Water-cooled	Туре:	Screw
		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e	441.0	acfm <sup>a,e</sup>
4*	Full Load Operating Pressure <sup>b</sup>	150	psig <sup>b</sup>
5	Maximum Full Flow Operating Pressure c	150	psig <sup>c</sup>
6	Drive Motor Nominal Rating	125	hp
7	Drive Motor Nominal Efficiency	95.4	percent
8	Fan Motor Nominal Rating (if applicable)	0.5	hp
9	Fan Motor Nominal Efficiency	76.2	percent
10*	Total Package Input Power at Zero Flow <sup>e</sup>	21.5	kW <sup>e</sup>
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	89.60	$kW^d$
12*	Package Specific Power at Rated Capacity and Full Load	20.32	kW/100 cfm <sup>e</sup>
	Operating Pressure <sup>e</sup>		
13	Isentropic Efficiency	81.41	Percent

Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Above 15

Member

No Load / Zero Volume Flow Rate Specific Energy at specified conditions Volume Flow Rate Consumption Flow Power ft<sup>3</sup> / min  $m^3 / min$ Below 17.6 Below 0.5 +/- 7 +/- 8 0.5 to 1.5 17.6 to 53 +/- 7 +/- 6 +/- 10% 53 to 529.7 1.5 to 15 +/- 5 +/- 6

+/- 4

+/- 5

ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

Above 529.7

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.