

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR											
1	Manufacturer: Kaishan Compressor USA										
	Model Number: KRSP-250-100 VSD				Date:		08/30/20				
2	X Air-cooled	X Air-cooled Water-cooled			Type:		Screw				
	Lubricated _				# of Stages:		1				
3*	Full Load Operating Pres	sure ^b	100 psig ^b		psig ^b						
4	Drive Motor Nominal Ra		25	0	hp						
5	Drive Motor Nominal Ef	ninal Efficiency		.2	percent						
6	Fan Motor Nominal Ratio	ng (if applicable)	7.5 &	21.5	hp						
7	Fan Motor Nominal Effic	r Nominal Efficiency		2 91.0	percent						
8*	Input Power (kW)		Capacity (acfm) ^{a,d}		Specific Power (kW/100 acfm) ^d						
	211.4		122	25	17.26						
	145.9		84	845 17.27							
	105.7		576		18.35						
	84.6		441		19.18						
	63.4		294		21.56						
9*	Total Package Input Power at Zero Flow c, d		0.0		kW						
10	Isentropic Efficiency	entropic Efficiency		52	%						
11	35.00 30.00 30.00 Specific Power (kW/100 ACFN) 25.00 15.00 10.00 0	Note: Graph is only a vis Note: Y-Axis Scale, 10 to 35,		rements if neces:		1200	1400				

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- CAGI Compressed Air & Gas Institute
- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

iviember

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.