

## **COMPRESSOR DATA SHEET**

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer: Kaishan Compressor USA								
	Model Number: KRSP-350-100 VSD			Date:	12	2/29/20			
2	X Air-cooled Water-cooled			Type:	S	Screw			
	X Lubricated		# of Stages:		1				
3*	Full Load Operating Pressure b		100	psig <sup>b</sup>					
4	Drive Motor Nominal Rating		350	hp					
5	Drive Motor Nominal Efficiency		96.2	percent					
6	Fan Motor Nominal Rating (if applicable)		15&4	hp					
7	Fan Motor Nominal Efficiency		91.7&89.1	percent					
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>					
	314.5		1875	16.77					
	207.6		1293	16.06					
	151.0		900	16.78					
	122.7		712	17.23					
	78.6		412	19.08					
9*	Total Package Input Power at Zero Flow c, d		0.0	kW		kW			
10	Isentropic Efficiency	Isentropic Efficiency		%		%			
11		Note: Graph is only a vis	800 1000 1200  Capacity (ACFM)  sual representation of the data in + 5kW/100acfm increments if neces 0 to 25% over maximum capacity		1800 2				

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>





- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

## Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1, 10,0
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.