## **COMPRESSOR DATA SHEET**



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MODEL DATA - FO	OR COMPRESSE	ED AIR				
1	Manufacturer: Kaishan Compressor USA							
	Model Number:	KRSP-60-100 VSD		Date:	08/30/20			
2	X Air-cooled Water-cooled			Type:	Screw			
				# of Stages:	1			
3*	Full Load Operating	Full Load Operating Pressure b			psig			
4	Drive Motor Nominal Rating		60		hp			
5	Drive Motor Nominal Efficiency		95.0		percent			
6	Fan Motor Nominal Rating (if applicable)		3		hp			
7	Fan Motor Nominal	Efficiency	89.5		percent			
8*	Input Power (kW	V)	Capacity (acfm) <sup>a,c</sup>	1	Specific Power (kW/100 acfm) <sup>d</sup>			
	58.2		300		19.40			
	40.2		214		18.79			
	30.1		148 20.34		20.34			
	24.7		117	21.11				
	16.9		73		23.15			
9*	Total Package Input Power at Zero Flow c, d				kW			
10	Isentropic Efficienc	Isentropic Efficiency 68.14 %						
11	35.0 30.0 Specific Power (KW)100 A CEM) 20.0	0 0 25 50 75 100  Note: Graph is only a v	125 150 175 2  Capacity (ACFM) isual representation of the data + 5kW/100acfm increments if ne		275 300 325			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
   NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.