COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer: Kaishan Compressor USA								
	Model Number	r: KRSP2	2-125-125 VSD		Date:	07/12/21			
2	X Air-o	cooled V	Water-cooled		Type: Screw				
					# of Stages:	2			
3*	Full Load Operating Pressure ^b			125	psig				
4	Drive Motor Nominal Rating			125	hp				
5	Drive Motor Nominal Efficiency			95.4	percent				
6	Fan Motor Nominal Rating (if applicable)			5	hp				
7	Fan Motor Nominal Efficiency			89.5	percent				
	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	109.8			620	17.71				
8*	90.0			496	18.15				
	78.0			434	17.97				
	58.2			310		18.77			
	47.2		1	248	19.03				
9*		Total Package Input Power at Zero Flow c, d			kW				
10	Isentropic Effi	Isentropic Efficiency			%				
11	Specific Power (KW/100 ACFM)		Note: Graph is only a vite: Y-Axis Scale, 10 to 35,	25 250 275 300 325 350 375 400 42 Capacity (ACFM) issual representation of the data in + 5kW/100acfm increments if neces 0 to 25% over maximum capacity	Section 8	50 575 600 625 650 675			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1/- 10/0
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.