

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR										
1	1 Manufacturer: Kaishan Compressor USA									
	Model Number: KRSP2-350-100 VSD			Date:	07/12/21					
2	X Air-cool	ed Water-cooled		Type:	Screw					
	X Lubricated Oil Free			# of Stages:	2					
3*	Full Load Operati	ng Pressure ^b	100	b psig						
4	Drive Motor Nom		350	hp						
5	Drive Motor Nom	Prive Motor Nominal Efficiency		percent						
6	Fan Motor Nomin	al Rating (if applicable)	15&4	hp						
7	Fan Motor Nomin	al Efficiency	91.7&89.1	percent						
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d						
	321.8		2068	15.56						
	263.9		1654	15.96						
	228.5		1448	15.78						
	170.6		1034	16.50						
	138.4		827	16.74						
9*	Total Package Input Power at Zero Flow c, d		0.0 83.31	kW						
10	Isentropic Efficier	Isentropic Efficiency		%						
11	Specific Power (RW/100 ACFM)	Note: Graph is only a vis Note: Y-Axis Scale, 10 to 35,	1000 1500 Capacity (ACFM) sual representation of the data in + 5kW/100acfm increments if neces 0 to 25% over maximum capacity		2500					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org





- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

iviember

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
m ³ /min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1, 10,0
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.