

## **COMPRESSOR DATA SHEET**

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR					
1	Manufacturer: Kaishan Compressor USA				
	Model Number: KRSI	P2-500-100 VSD		Date:	07/12/21
2	X Air-cooled	Water-cooled		Type:	Screw
	Lubricated Oil Free		<del>,</del>	# of Stages:	2
3*	Full Load Operating Pressure <sup>b</sup>		100	psig <sup>b</sup>	
4	Drive Motor Nominal Rating		500	hp	
5	Drive Motor Nominal Efficiency		96.2	percent	
6	Fan Motor Nominal Rating (if applicable)		3(4)	hp	
7	Fan Motor Nominal Efficiency		89.5	percent	
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>	
	448.4		2947	15.22	
	367.7		2358	15.59	
	318.4		2063	15.43	
	237.7		1474	16.13	
	192.8		1179	16.35	
9*	Total Package Input Power at Zero Flow c, d		0.0	kW	
10	Isentropic Efficiency		85.21	%	
11	35.00 30.00 30.00 25.00 20.00 15.00 0	Note: Graph is only a vie Note: Y-Axis Scale, 10 to 35,	1500 2000  Capacity (ACFM)  sual representation of the data in: + 5kW/100acfm increments if neces 0 to 25% over maximum capacity	Section 8	3000 3500

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>





- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

## Volume Flow Rate Specific Energy Zero Flow at specified conditions Volume Flow Rate Consumption Power ft<sup>3</sup> / min $\underline{m^3} / \underline{min}$ Below 17.6 +/- 7 Below 0.5 +/- 8 17.6 to 53 0.5 to 1.5 +/- 6 +/- 7 +/- 10% 1.5 to 15 53 to 529.7 +/- 5 +/- 6 Above 529.7

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.